

3

DISTRICT WATER TESTING LABORATORY, FEROZPUR

Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfr@gmail.com

To,

Janak Raj

J.N International Sr. Sec. School Village-Saide Ke Mohan, Ferozpur-Fazilka Road, Ferozpur

No.: DWTL/FZR/2324/00018 Dated : 11/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 100/JN/2023/C76 Dated: 08/05/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 08/05/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Ferozpur

D/A : Test Report

Manoj Kumar

Authorized Signatory
For, District Water Testing Laboratory,
Ferozpur



Principal
J. N. International School
Saide Ke Mohan F-F Road
District Ferozpur

DISTRICT WATER TESTING LABORATORY, FEROZPUR

Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfr@gmail.com




TEST REPORT

Name & Address of Customer : Janak Raj J.N International Sr. Sec. School Village-Saide Ke Mohan, Ferozepur-Fazilka Road, Ferozepur	Customer Reference No. No : 100/JN/2023/C76 Dated : 08/05/2023 Sample Submitted by Janak Raj Date of Sample Receipt 08/05/2023 Analysis Starting Date 09/05/2023 Analysis completion Date 10/05/2023
----------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC103752300000056F	Sample Type :	Water
Test Report No.:	DWTL/FZR/2324/00018	Date of Issue :	11/05/2023
Registration no.:	DWTL/FZR/REG2324/00175	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	J.N International Sr. Sec. School Village-Saide Ke Mohan, Ferozepur-Fazilka Road, Ferozepur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Guru Harsahai	District :	Ferozepur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.60	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	100	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	60	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	60	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	17.6	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	3.8	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method


 J. N. International School
 Saide Ke Mohan, F-F Road
 District Ferozepur

DISTRICT WATER TESTING LABORATORY, FERAZPUR

Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfzr@gmail.com



11	Chloride	30	750	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---------------------------------------------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable, NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND = Not Detected.
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Mrs. Manju
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory,
Ferozpur

----- End of the Test Report -----

Principal
J. N. International School
Salde ke Mohan F-F Road
District Ferozpur